

制気ロリスト(1)														
階	部屋名	系統名	吹出口・吸込口						BOXサイズ					備考
			用途	風量 m3/h	個 数	合計風量 m3/h	器具 名称	結露防止 仕様	サイズ mm × mm	W × D	H	内貼		
1	保健室	HEU-1-12	SA	180	1	180	VHS		200 × 200	400 × 400	× 350		GW25t	
	〃	HEU-1-12	RA	180	1	180	HS		200 × 200	400 × 400	× 350			
	前室		OA	70	1	70	VHS (F付)		150 × 150	350 × 350	× 350		GW25t	
	SW (保健室横)	FE-1-12	EA	20	1	20	HS		150 × 150	350 × 350	× 300			
	WC (保健室横)	FE-1-13	EA	50	1	50	HS		150 × 150	350 × 350	× 300			
	会議室	HEU-1-15	SA	495	2	990	VHS		300 × 300	500 × 500	× 450		GW25t	
	〃	HEU-1-15	RA	495	2	990	HS		300 × 300	500 × 500	× 450			
	給湯休憩室		OA	120	1	120	VHS (F付)		150 × 150	350 × 350	× 350		GW25t	
	〃	FE-1-7	EA	120	1	120	HS		150 × 150	350 × 350	× 400			
	印刷室		OA	230	1	230	VHS		250 × 250	400 × 400	× 350		GW25t	
	〃	FE-1-6	EA	230	1	230	HS		200 × 200	400 × 400	× 400			
	校務センター	HEU-1-8	SA	690	2	1,380	VHS		350 × 350	550 × 550	× 450		GW25t	
	〃	HEU-1-8	RA	690	2	1,380	HS		350 × 350	550 × 550	× 450			
	校長室	HEU-1-9	SA	90	1	90	VHS		150 × 150	350 × 350	× 350		GW25t	
	〃	HEU-1-9	RA	90	1	90	HS		150 × 150	350 × 350	× 350			
	事務室	HEU-1-10	SA	90	1	90	VHS		150 × 150	350 × 350	× 350		GW25t	
	〃	HEU-1-10	RA	90	1	90	HS		150 × 150	350 × 350	× 350			
	共同学校事務室	HEU-1-11	SA	50	1	50	VHS		150 × 150	350 × 350	× 300		GW25t	
	〃	HEU-1-11	RA	50	1	50	HS		150 × 150	350 × 350	× 300			
	メディアセンター	HEU-1-2	SA	500	2	1,000	VHS		300 × 300	500 × 500	× 450		GW25t	
	〃	HEU-1-2	RA	500	2	1,000	HS		300 × 300	500 × 500	× 450			
	生徒指導室	HEU-1-16	SA	210	1	210	VHS		200 × 200	400 × 400	× 400		GW25t	
	〃	HEU-1-16	RA	210	1	210	HS		200 × 200	400 × 400	× 400			
	HWC	FE-1-30	EA	230	1	230	HS		200 × 200	400 × 400	× 400			
	倉庫1	FE-1-11	EA	160	1	160	HS		200 × 200	400 × 400	× 350			
	職員用WC	FE-1-29	EA	110	2	220	HS		150 × 150	350 × 350	× 350			
	女性職員更衣室	FE-1-10	EA	115	2	230	HS		150 × 150	350 × 350	× 350			
	男性職員更衣室	FE-1-9	EA	115	2	230	HS		150 × 150	350 × 350	× 350			
	書庫準備室	FE-1-8	EA	100	1	100	HS		150 × 150	350 × 350	× 350			
	通級学級	HEU-1-1	SA	140	1	140	VHS		150 × 150	350 × 350	× 350		GW25t	
	〃	HEU-1-1	RA	140	1	140	HS		150 × 150	350 × 350	× 350			
	教育相談室	HEU-1-14	SA	90	1	90	VHS		150 × 150	350 × 350	× 350		GW25t	
	〃	HEU-1-14	RA	90	1	90	HS		150 × 150	350 × 350	× 350			
	カウンセリング室	HEU-1-13	SA	90	1	90	VHS		150 × 150	350 × 350	× 350		GW25t	
	〃	HEU-1-13	RA	90	1	90	HS		150 × 150	350 × 350	× 350			
	消火ポンプ室	FE-1-3	EA	370	1	370	HS		250 × 250	450 × 450	× 400			
	特別活動室	HEU-1-6	SA	200	1	200	VHS		200 × 200	400 × 400	× 400		GW25t	
	〃	HEU-1-6	RA	200	1	200	HS		200 × 200	400 × 400	× 400			
	MWC1-1	FE-1-4	EA	140	5	700	HS		200 × 200	400 × 400	× 350			
	HWC1	FE-1-4	EA	120	1	120	HS		200 × 200	400 × 400	× 350			
	誰でもトイレ	FE-1-4	EA	80	1	80	HS		150 × 150	350 × 350	× 400			
	MWC1-1	FE-1-5	EA	140	7	980	HS		300 × 300	500 × 500	× 350			
	グループ学習室	HEU-1-3	SA	240	2	480	VHS		200 × 200	400 × 400	× 400			
	〃	HEU-1-3	RA	240	2	480	HS		200 × 200	400 × 400	× 400			
	アートギャラリー (技術室)	HEU-1-4	SA	410	2	820	VHS		250 × 250	450 × 450	× 450		GW25t	
	〃	HEU-1-4	RA	410	2	820	HS		250 × 250	450 × 450	× 450			
	技術準備室	HEU-1-5	SA	120	1	120	VHS		150 × 150	350 × 350	× 350			
	〃	HEU-1-5	RA	120	1	120	HS		150 × 150	350 × 350	× 350			
	屋外倉庫		OA	700	1	700	VHS		350 × 350	550 × 550	× 450		GW25t	
	〃	FE-1-18	EA	700	1	700	HS		350 × 350	550 × 550	× 450			
	MWC1-2・HWC2	FE-1-16	EA	176	5	880	HS		250 × 250	450 × 450	× 350			
	MWC1-2	FE-1-17	EA	135	4	540	HS		200 × 200	400 × 400	× 350			
	配膳室		OA	440	1	440	VHS (F付)		300 × 300	500 × 500	× 450		GW25t	
	〃	FE-1-26	EA	440	1	440	HS		300 × 300	500 × 500	× 450			
	荷受室2		OA	380	1	380	VHS (F付)		300 × 300	450 × 450	× 400		GW25t	
	〃	FE-1-28	EA	380	1	380	HS		250 × 250	450 × 450	× 400			
	荷受室1		EA	80	1	80	HS		150 × 150	350 × 350	× 350			
	〃	FE-1-27	EA	80	1	80	HS		150 × 150	350 × 350	× 350			
	検収室		OA	230	1	230	VHS (F付)		250 × 250	400 × 400	× 400		GW25t	
	〃	FE-1-21	EA	230	1	230	HS		200 × 200	400 × 400	× 400			
	下処理室		OA	185	2	370	VHS (F付)		200 × 200	400 × 400	× 400		GW25t	
	〃	FE-1-25	EA	185	2	370	HS		200 × 200	400 × 400	× 400			
	食品庫		OA	120	1	120	VHS (F付)		150 × 150	350 × 350	× 350		GW25t	
	〃	FE-1-24	EA	120	1	120	HS		150 × 150	350 × 350	× 350			
	休憩室	HEU-1-7	SA	180	1	180	VHS		200 × 200	400 × 400	× 350		GW25t	
	〃	HEU-1-7	RA	180	1	180	HS		200 × 200	400 × 400	× 350			
	WC	FE-1-20	EA	100	1	100	HS		150 × 150	350 × 350	× 350			
	更衣室・押入		OA	50	2	100	VHS (F付)		150 × 150	350 × 350	× 350		GW25t	
	〃	FE-1-22	EA	50	2	100	HS		150 × 150	350 × 350	× 300			
	前室		OA	310	1	310	VHS (F付)		250 × 250	450 × 450	× 400		GW25t	
	〃	FE-1-23	EA	310	1	310	HS		250 × 250	450 × 450	× 400			
	通路		OA	440	1	440	VHS (F付)		300 × 300	500 × 500	× 450		GW25t	
	〃	FE-1-19	EA	440	1	440	HS		300 × 300	500 × 500	× 450			
	調理室	RFT-1	SOA	1,990	4	7,960	VHS		550 × 550	750 × 750	× 550		GW25t	
	〃	FS-1-1	OA	2,660	3	7,980	VHS		650 × 650	850 × 850	× 600		GW25t	
	洗浄室	FS-1-2	OA	2,060	1	2,060	VHS		600 × 600	800 × 800	× 550		GW25t	
	〃	FE-1-1-2	EA	390	4	1,560	HS		250 × 250	450 × 450	× 400			
	玄関 5		OA	2,370	1	2,370	VHS (F付)		700 × 700	800 × 800	× 600		GW25t	

階	部屋名	系統名	用途	吹出口・吸込口					BOXサイズ					備考	
				風量 m3/h	個 数	合計風量 m3/h	器具 名称	結露防止 仕様	サイズ mm × mm	W	×	D	×		H
	MWC1-3・HWC2	FE-1-14	EA	90	6	520	HS		200 × 200	400	×	400	×	325	
	MWC1-3	FE-1-15	EA	180	3	540	HS		350 × 350	500	×	500	×	325	
	エントランスホール	FE-1-32	EA	1,130	6	189	HS		200 × 200	400	×	400	×	400	
	器具庫	FE-1-2	EA	680	1	1,360	HS		350 × 350	550	×	550	×	450	
	廊下A		PASS	1,360	1	1,360	VHS		550 × 550	650	×	650	×	525	GW25t
	体育教官室	HEU-1-18	SA	60	1	60	VHS		150 × 150	350	×	350	×	300	GW25t
	廊下2	HEU-1-18	RA	60	1	60	HS		150 × 150	350	×	350	×	300	
	講堂兼屋内運動場	ACP-A-1	SOA	2,100	4	525	VHS		600 × 150	800	×	350	×	500	GW25t
	講堂兼屋内運動場	ACP-1-5-1	SA	360	30	30,600	ノズル		#12	650	×	550	×	300	GW25t
	放送室	HEU-1-17	RA	665	6	4,000	ノズル		#12	550	×	550	×	500	
	放送室	HEU-1-19	SA	90	1	90	VHS		150 × 150	350	×	350	×	300	GW25t
	廊下B	HEU-1-19	RA	90	1	90	HS		150 × 150	350	×	350	×	300	
2	CR2-1	HEU-2-1	SA	410	2	820	VHS		250 × 250	450	×	450	×	450	GW25t
	廊下C	HEU-2-1	RA	410	2	820	HS		250 × 250	450	×	450	×	450	
	CR2-2	HEU-2-2	SA	410	2	820	VHS		250 × 250	450	×	450	×	450	GW25t
	廊下D	HEU-2-2	RA	410	2	820	HS		250 × 250	450	×	450	×	450	
	CR2-3	HEU-2-3	SA	410	2	820	VHS		250 × 250	450	×	450	×	450	GW25t
	廊下E	HEU-2-3	RA	410	2	820	HS		250 × 250	450	×	450	×	450	
	CR2-4	HEU-2-4	SA	410	2	820	VHS		250 × 250	450	×	450	×	450	GW25t
	廊下F	HEU-2-4	RA	410	2	820	HS		250 × 250	450	×	450	×	450	
	CR2-5	HEU-2-5	SA	410	2	820	VHS		250 × 250	450	×	450	×	450	GW25t
	廊下G	HEU-2-5	RA	410	2	820	HS		250 × 250	450	×	450	×	450	
	少人数教室	HEU-2-6	SA	220	1	220	VHS		200 × 200	400	×	400	×	400	GW25t
	廊下H	HEU-2-6	RA	220	1	220	HS		200 × 200	400	×	400	×	400	
	被服準備室	HEU-2-11	SA	120	1	120	VHS		150 × 150	350	×	350	×	350	GW25t
	廊下I	HEU-2-11	RA	120	1	120	HS		150 × 150	350	×	350	×	350	
	家庭科室(被服室)	HEU-2-10	SA	274	2	548	VHS		250 × 250	450	×	450	×	400	GW25t
	廊下J	HEU-2-10	RA	274	2	548	HS		250 × 250	450	×	450	×	400	
	特別支援学級	HEU-2-7	SA	170	2	340	VHS		200 × 200	400	×	400	×	350	GW25t
	廊下K	HEU-2-7	RA	170	2	340	HS		200 × 200	400	×	400	×	350	
	MWC2-1	FE-2-4	EA	140	5	700	HS		200 × 200	400	×	400	×	350	
	HWC4	FE-2-4	EA	120	1	120	HS		200 × 200	400	×	400	×	350	
	誰でもトイレ	FE-2-4	EA	80	1	80	HS		150 × 150	350	×	350	×	400	
	MWC2-1	FE-2-5	EA	140	7	980	HS		300 × 300	500	×	500	×	350	
	配膳室	OA	330	1	330	VHS		250 × 250	450	×	450	×	400	GW25t	
	廊下L	FE-2-3	EA	330	1	330	HS		250 × 250	450	×	450	×	400	
	教材室	FE-2-8	EA	290	1	290	HS		250 × 250	450	×	450	×	400	
	MWC2-2	FE-2-6	EA	143	4	570	HS		250 × 250	450	×	450	×	350	
	MWC2-2・HWC5	FE-2-7	EA	138	5	690	HS		200 × 200	400	×	400	×	350	
	調理準備室	HEU-2-9	SA	120	1	120	VHS		150 × 150	350	×	350	×	350	GW25t
	廊下M	HEU-2-9	RA	120	1	120	HS		150 × 150	350	×	350	×	350	
	家庭科室(調理室)	HEU-2-8	SA	274	3	822	VHS		250 × 250	450	×	450	×	400	GW25t
	廊下N	HEU-2-8	RA	274	3	822	HS		250 × 250	450	×	450	×	400	
	部室8	FE-2-19	EA	290	1	290	HS		250 × 250	450	×	450	×	400	
	更衣室(男子)	FE-2-9	EA	195	2	390	HS		200 × 200	400	×	400	×	400	
	更衣室(女子)	FE-2-10	EA	180	2	360	HS		200 × 200	400	×	400	×	350	
	シャワールームA・B	FE-2-11	EA	90	2	180	HS		150 × 150	350	×	350	×	350	
	武道場	HEU-2-12	SA	342	5	1,710	VHS		250 × 250	450	×	450	×	400	GW25t
	廊下O	HEU-2-12	RA	342	5	1,710	HS		250 × 250	450	×	450	×	400	
	多目的室	HEU-2-13	SA	975	2	1,950	VHS		400 × 400	600	×	600	×	500	GW25t
	廊下P	HEU-2-13	RA	975	2	1,950	HS		400 × 400	600	×	600	×	500	
	器具庫2	FE-2-1	EA	680	1	680	HS		350 × 350	550	×	550	×	450	
	廊下Q		PASS	680	1	680	VHS		350 × 350	550	×	550	×	450	
	器具庫3	FE-2-2	EA	540	1	540	HS		300 × 300	500	×	500	×	450	
	廊下R		PASS	540	1	540	VHS		300 × 300	500	×	500	×	450	
	廊下C		OA	3,980	1	3,980	VHS(F付)		800 × 800	1000	×	1000	×	650	
	部室1	FE-2-12	EA	240	1	240	HS		200 × 200	400	×	400	×	400	
	部室2	FE-2-13	EA	230	1	230	HS		200 × 200	400	×	400	×	400	
	部室3	FE-2-14	EA	240	1	240	HS		200 × 200	400	×	400	×	400	
	部室4	FE-2-15	EA	240	1	240	HS		200 × 200	400	×	400	×	400	
	部室5	FE-2-16	EA	240	1	240	HS		200 × 200	400	×	400	×	400	
	部室6	FE-2-17	EA	260	1	260	HS		200 × 200	400	×	400	×	400	
	部室7	FE-2-18	EA	270	1	270	HS		200 × 200	400	×	400	×	400	
	部室8	FE-2-19	EA	290	1	290	HS		200 × 200	400	×	400	×	400	
	多目的スペース	ACP-B-1	SOA	1,080	1	1,080	VHS		400 × 400	600	×	600	×	500	GW25t
	廊下S	ACP-B-2	SOA	2,100	1	2,100	VHS		600 × 600	800	×	800	×	550	GW25t
	家庭科室(調理室)	FE-2-20	EA	174	9	1,566	HS		200 × 200	400	×	400	×	350	
	廊下T		OA	783	2	1,566	VHS(F付)		350 × 350	550	×	550	×	450	